



Certificate of Compliance

Certificate: 2509560

Master Contract: 190952

Project: 80118551

Date Issued: 2022-03-30

Issued To: Quadritalia S.r.l.
Via Mattei 6/10
Brendola, Vicenza, 36040
Italy

Attention: Flavio Sanson

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.

Issued by: Azad Hacika
Azad Hacika



PRODUCTS

CLASS - C321191 - INDUSTRIAL CONTROL EQUIPMENT Enclosures for Electrical Equipment – US Requirements

CLASS - C321111 - INDUSTRIAL CONTROL EQUIPMENT Enclosures for Electrical Equipment

Industrial Control Panel Enclosures, Series OK K (disassembled, supplied as a kit) and OK B (preassembled), painted sheet steel, floor standing, for indoor use, rated Type 1 and 12.

Notes:

- These component enclosures are intended for the installation of industrial electrical equipment where the complete assembly is approved for installation in non-hazardous locations in accordance with the Canadian Electrical Code Part I and the National Electrical Code.



Certificate: 2509560
Project: 80118551

Master Contract: 190952
Date Issued: 2022-03-30

-
- The full enclosure model codes/catalogue designations may be completed by suffixes indicating dimensions, mechanical details, and accessories that may be provided or supplied with the enclosures (see Attachment 2 of report for further details).
 - Assembly and/or mounting and/or installation instructions/sheets are provided with each enclosure/accessory.

APPLICABLE REQUIREMENTS

Canadian Standards

- | | |
|-----------------------|---|
| CSA C22.2 No. 0-20 | - General Requirements - Canadian Electrical Code, Part II |
| CSA C22.2 No. 94.1-15 | - Enclosures for Electrical Equipment, Non-Environmental Considerations |
| CSA C22.2 No. 94.2-15 | - Enclosures for Electrical Equipment, Environmental Considerations |

US Standards

- | | |
|------------------------------|---|
| UL 50 (13 th ed.) | - Enclosures for Electrical Equipment, Non-Environmental Considerations |
| UL 50E (2 nd ed.) | - Enclosures for Electrical Equipment, Environmental Considerations |

Notes:

Products certified under Class C321111 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 2509560

Master Contract: 190952

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80118551	2022-03-30	Update to Report 2509560 for addition of alternative gasket material according to FIR report 190953-201026 and 190953-211014. Report shall be updated to the latest requirements of CSA C22.2 No. 94.1-15/UL50 and CSA C22.2 No. 94.2-15/UL50E.
2509560	2012-05-21	Original Certification of Industrial Control Panel Enclosures, Series OK K and OK B painted sheet steel, floor standing, for indoor use, rated Type 1 and 12 according to CSA C22.2 No 0-10, 94.1-07, 94.2-07; UL 50 (2007, 12th ed.), UL50E (2007, 12th ed.).